



Central Plains Cement Company

Cement Mill Test Report

Month of Issue: October 2018

Plant:	Tulsa, OK
Product:	Portland Cement Type V
Silos:	5,A
Manufactured:	September 2018

ASTM C 150-16 and AASHTO M 85-16 Standard Requirements

CHEMICAL ANALYSIS			PHYSICAL ANALYSIS		
Item	Spec limit	Test Result	Item	Spec limit	Test Result
Rapid Method, X-Ray (C 114)			Air content of mortar (%) (C 185)	12 max	6
SiO ₂ (%)	---	20.6	Blaine Fineness (m ² /kg) (C 204)	260 min	444
Al ₂ O ₃ (%)	---	3.9	-325 (%) (C 430)	---	94.2
Fe ₂ O ₃ (%)	---	4.6	Autoclave expansion (%) (C 151)	-0.2 min 0.80 max	-0.04
CaO (%)	---	62.7	Compressive strength (PSI) (C 109)		
MgO (%)	6.0 max	1.8	1 day	---	2090
SO ₃ (%)	2.3 max*	3.1	3 days	1160 min	3670
Loss on ignition (%)	3.0 max	1.0	7 days	2180 min	4400
Insoluble residue (%)	0.75 max	0.42	28 days (Reflects previous month's data)	3050 min	5690
CO ₂ (%)	---	0.2	Time of setting (minutes)		
Limestone (%)	5.0 max	---	Vicat Initial (C 191)	45 - 375	120
CaCO ₃ in Limestone (%)	70 min	---			
Inorganic Process Addition	5.0 max	---			
Adjusted Potential Phase Composition (C 150)					
C ₃ S (%)	---	58			
C ₂ S (%)	---	15			
C ₃ A (%)	5 max	2			
C ₄ AF (%)	---	14			
C ₄ AF+2*C ₃ A (%)	25 max	18			

ASTM C 150-16 and AASHTO M 85-16 Optional Chemical Requirements:

NaEq (%)	---	0.41
----------	-----	------

* Cement with SO₃ > 2.3 complies with ASTM C1038-10

We certify that the above described cement, at the time of shipment, meets the chemical and physical requirements of ASTM C 150-16 & AASHTO M 85-16 STANDARD SPECIFICATIONS FOR TYPE V CEMENT.

Certified By:

John Tierney

Central Plains Cement Co. LLC - Tulsa Plant
2609 North 145th East Ave
Tulsa, OK 74012
918-437-3902

October 11, 2018